







## WEAKENED PLANE JOINT

## SECTION A-A

## Notes:

- Weakened plan joints shall be constructed at ends of curb returns, curb inlets, other structures and at 12' intervals except in driveway sections. Joints shall match adjacent improvements.
- 2. Concrete shall be class 'A' or an approved 3000psi mix with a light broom finish.
- 3. Score lines shall be 1/4" deep.
- Aggregate base shall be 8" thick where constructing next to existing sidewalk or curbs without dowels.
- 5. Meandering sidewalk shall be within PSUE as shown on plans.
- △ 6. Industrial sidewalk shall be constructed on both sides of the street.

CITY OF MILPITAS, ENGINEERING DIVISION					STANDARD DRAWING
REVISION	DATE	DESIGNED; MK	INDUSTRIAL		NO. 425
$\triangle$		DRAWN: TS			
		CHECKED: 3K	SIDEWALK	_	ORIGINAL: 1/21/75
		APPROVED B	CITY ENGINEER	DATE: 10/23/01	SHEET 1 OF 1